

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Inspection/2023

Dated: 28-Apr-2023

It is certified that an inspection team headed by Dr. D.K KOHLI

(Name of Officers with designation) from PHC Bailparao, Ramnagar, (Nainital)

(Name of Department/ Office) inspected the Medical Health Team Garden Valley Public School Gaujani, Ramnagar on 28-APR-2023 (date of inspection) and found that the Garden Valley Public School Gaujani, Ramnagar. has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ONE YEAR

Signature with Seal:


Name

Designation

Name & Address of the Office / Department :

To

Garden Valley Public School
Gaujani, Ramnagar


प्रभारी चिकित्साधिकारी
प्राथमिक स्वास्थ्य केंद्र
बैलपड़ाव..(नैनीताल).....



QUALITY TESTING & RESEARCH CENTRE

क्वालिटी टेस्टिंग एवम् रिसर्च सेंटर

GOVT. APPROVED NABL ACCREDITED LABORATORY

KHASRA NO. 67. M, GANGAPUR RAQBA, KASHIPUR, UDHAM SINGH NAGAR, UTTARAKHAND-244713

Phone No : 9654270388, 8700914896

Website : <https://qualitytestingcentre.org>, E-mail: qualitytestingcentre@gmail.com

TEST REPORT

Sample / Report No.		QTRC/9120240109/01			Page 1 of 1	
Name and Address of Customer		GARDEN VALLEY PUBLIC SCHOOL Add:- Gaujani, P.O.:- Ramnagar, Distt:- Nainital, Uttarakhand				
Description of Sample		Drinking Water				
Agreement No.		--				
Reference No.		--		Date of Receipt		09/01/2024
Name of Work		--		Start Date of Analysis		09/01/2024
Name of Agency		--		End Date of Analysis		16/01/2024
Indian Standard of Ref.		IS:10500:2012		Report Issue Date		16/01/2024
S. No.	Test Parameters	Units	Results	Requirement AS PER IS: IS:10500-2012		Test Method
				Acceptable Limit	Permissible Limit	
CHEMICAL PARAMETERS						
1.	Colour	Hazen unit	Less than 1	5.0 Max	15.0 Max	IS:3025(P-4)2021
2.	pH value	--	7.12	6.5-8.5	No Relaxation	IS:3025(P-11)2022
3.	Turbidity	NTU	0.14	1.0 Max	5.0 Max	IS:3025(P-10)1984
4.	Total Dissolved Solids	mg/l	242	500 Max	2000 Max	IS:3025(P-16)1984
5.	Chloride (as Cl)	mg/l	24	250 Max	1000 Max	IS:3025(P-32)1988
6.	Total Hardness (as CaCO ₃)	mg/l	87	200 Max	600 Max	IS:3025(P-21)2009
7.	Calcium as Ca	mg/l	28	75 Max	200 Max	IS:3025(P-40)1991
8.	Magnesium (as Mg)	mg/l	3.46	30 Max	100 Max	IS:3025(P-46)1983
9.	Total Alkalinity (as CaCO ₃)	mg/l	120	200 Max	600 Max	IS:3025(P-23)1983
10.	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(P-5)2018
11.	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(P-8)1983
12.	Iron (as Fe)	mg/l	BDL(DL-0.1)	0.3 Max	No Relaxation	IS:3025(P-53)1983
Microbiological Examination						
1.	E. Coli per 100 ml	Per 100ml	Absent	Shall not be Detectable in any 100 ml. sample		IS:15185:2016
2.	Coli form per 100ml	Per 100ml	Absent	Shall not be Detectable in any 100 ml. sample		IS:15185:2016

Note:- BDL-Below Detection Limit., DL: - Detection Limit

Remarks: The Sample conforms to IS: 10500:2012 FOR acceptable limits with respect to above tests only.

**** End of Test Report****

Authorized Signatory

AN ISO / IEC 17025 : 2017, ISO 9001 : 2015, ISO 14001 : 2015 CERTIFIED LABORATORY

Note : certified that the test enumerated above have been carried out in conformity with standard testing procedures and relevant specification. The refers ONLY to the particular sample(s) submitted for test. The report should not be utilised for any legal purpose and will not be produced in the court of law. Sample Description is not verified in all cases and is given as described by Customer, All Complaints about this should be communicated in writing within 10days from the date of issue of this report. Except by special arrangement, Samples, if drawn, will not be retained by the company for more than 30 days. This test report is not to be reproduced except in full, without written approval of the Laboratory.