

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No: Inspection 2025

Date: 23/05/2025

It is certified that an inspection team headed by Dr. D.K KOHLI
 From PHC Bailparao, Ramnagar (Nainital) (Name of Department / Office) inspected
 the Medical Health Team Garden Valley Public School Gaujani, Ramnagar (Name &
 Address of the School) on 23/05/2025 (Date Of Inspection) and found that the
Garden Valley Public School Gaujani (Ramnagar) (Name Of The School) has safe
 drinking water facilities for the students and members of staff of the Institution and is
 maintaining the hygienic sanitation condition in the school building and the campus
 as per the norms prescribed by the center/state/UK Govt.

The above is valid for the period of One year.

AP
 Name with Seal:

Name: Dr. D.K. Kohli

Designation: Medical Officer

प्रभारी चिकित्साधिकारी
 प्राथमिक स्वास्थ्य केन्द्र
 बैलपराव नैनीताल

To,

Garden Valley Public School

Gaujani, Ramnagar, NTL

Garden Valley Public School
Manager





Sub Divisional Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Ramnagar

Phone No.: 05947-251350,

E-mail: eeram.ujs.uk@gmail.com

Report ID: 19/SDLWQTML/UJS/RN/2025-26

Date: 19/05/2025

Water Quality Test Report

Name & Address of Organization / Customer	Garden Valley Senior Secondary School Gaujani Ramnagar Nainital (Uttarakhand)		
Product Description (Surface Water/Ground water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample Collected from Garden Valley Senior Secondary School Gaujani Ramnagar Nainital
Reference Sample Identification :	19/SDLWQTML/UJS/RN/2025-26	Date of Start of Analysis:	16/05/2025
Date & Time of Sample Received: 16-05-2025&10:30 AM	Sample Collected By:	Date of End of Analysis:	19/05/2025
		Customer	

Testing Details

(A) Chemical Test

S.N.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH@25°C	7.23	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/l	211	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	3.42	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/l	158	200	600	IS 3025 Pt-23-2019
5.	Total Hardness (as CaCO ₃), mg/l	198	200	600	IS 3025 Pt-21-2002
6.	Calcium (as Ca), mg/l	48.8	75	200	IS 3025 Pt-40-2019
7.	Magnesium (as Mg), mg/l	18.4	30	100	APHA 23 rd Ed-3500-Mg-B:2017
8.	Chloride, mg/l	9.4	250	1000	IS 3025 Pt-32 : 2019
9.	Colour, Hazen	5	5	15	IS 3025 Pt-04 : 2021
10.	Odour	AGREE	Agreeable	Agreeable	IS 3025 Pt-05: 2018
11.	Taste	AGREE	Agreeable	Agreeable	IS 3025 Pt-08: 2012
12.	Residual Free Chlorine (FRC), mg/l	ND*	0.2	1.0	IS 3025 Pt-26:2021

(B) Bacteriological Test

13.	E.coli	ABSENT	Absent	Absent	APHA 23 rd -9223
14.	Total Coliform	ABSENT	Absent	Absent	APHA 23 rd -9223

ND*: Not Detectable

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Garden Valley Senior Secondary School

Quality Manager
Sub-Divisional Level
Water Quality Testing & Monitoring Laboratory

End of Report

Analyst
SDLWQTML, UJS, Ramnagar (Nainital)
Ramnagar Nainital (Uttarakhand)

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.