

APPENDIX - XII

FIRE SAFETY CERTIFICATE

No. CFO-NO-6(E)/2022

Dated:16-MAY-2023

Certified that the GARDEN VALLEY PUBLIC SCHOOL at BASANT KUNJ GAUJANI, RAMNAGAR comprised of 0(ZERO) basement(s) and G+3 (upper floors) owned/occupied by GARDEN VALLEY PUBLIC SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 16-MAY-2023 in the presence of MANAGER (Kripal Singh Mehra) and that the building/ premises is fit for occupancy up to classes (XI & XII) With effect from 16-MAY-2023 to 15-APR-2026 for a period of 3 year in accordance with rule and subject to compliance of specific conditions: -

1. In case of Expansion of extra area the school will follow NBC-2016 of part-4 rules.
2. School will keep water reserve every time.
3. All the fire exit area should be barrier free.
4. No electric gadgets should be stored around the electric switch boards/panels

Issued on 16-MAY-2023 at OFFICE OF CHIEF FIRE OFFICER (NAINITAL)

*Strike out whichever is not applicable.

Signature with Seal
NAME
DESIGNATION
Name & Address of Department Office:



To
MANAGER
GARDEN VALLEY PUBLIC SCHOOL
(GAUJANI) RAMNAGAR



Garden Valley Public School
Manager